



DELAWARE STATE FIRE MARSHAL STANDPIPE SYSTEMS DEFICIENCY REPAIR FORM



PROTECTED PROPERTY

Name: _____ Owner/Contact: _____
Address/City: _____ Phone Number: _____

SUPPRESSION SYSTEM COMPANY AND REPAIR DATE

Company Name: _____ FSL #: _____
Technician's Name: _____ Repair Date: _____

SYSTEM INFORMATION

System ID Number: _____ Location: _____
System Type: ☐ Wet Standpipe ☐ Dry Standpipe ☐ Other
Operation: ☐ Manual ☐ Semi-Automatic ☐ Automatic

MAJOR DEFICIENCIES CORRECTED

HOSE CONNECTIONS

- ☐ 7501 – Visible Obstructions
- ☐ 7502 – Fire Hose Connection Damaged
- ☐ 7503 – Valve Handles Missing
- ☐ 7504 – Valve Leaking

PIPING

- ☐ 7505 – Damaged Piping

MINOR DEFICIENCIES CORRECTED

HOSE CONNECTIONS

- ☐ 7550 – Cap Missing
- ☐ 7551 – Cap Gasket Missing or Deteriorated
- ☐ 7552 – Restricting Device Missing
- ☐ 7553 – Manual, Semi-Automatic or Dry-Standpipe—Valve Does Not Operate Smoothly

PIPING

- ☐ 7554 – Control Valves Damaged
- ☐ 7555 – Missing or Damaged Pipe Support Devices
- ☐ 7556 – Damaged Supervisory Devices

HOSE

- ☐ 7557 – Hose Missing
- ☐ 7558 – Hose Damaged or In Poor Condition

HOSE NOZZLE

- ☐ 7559 – Hose Nozzle Missing
- ☐ 7560 – Gasket Missing or Deteriorated
- ☐ 7561 – Nozzle Does Not Operate Smoothly

NONE ☐ CHECKED BELOW ☐

CABINET

- ☐ 7506 – Visible Obstructions

HOSE STORAGE DEVICE

- ☐ 7507 – Obstruction
- ☐ 7508 – Other (Comment Below)

NONE ☐ CHECKED BELOW ☐

HOSE STORAGE DEVICE

- ☐ 7562 – Difficult to Operate
- ☐ 7563 – Damaged
- ☐ 7564 – Hose Improperly Racked or Rolled
- ☐ 7565 – Nozzle Clip In Place and Nozzle Correctly Contained
- ☐ 7566 – If Exposed In Cabinet, Will Hose Rack Swing Out At Least 90 Degrees?

CABINET

- ☐ 7567 – Difficult to Open
- ☐ 7568 – Cabinet Door Will Not Open Fully
- ☐ 7569 – Door Glazing Cracked or Broken
- ☐ 7570 – If Cabinet Is Break-Glass Type, Is Lock Functioning Properly?
- ☐ 7571 – Glass Break Device Is Missing or Not Attached
- ☐ 7572 – Not Properly Identified As Containing Fire Equipment
- ☐ 7573 – All Valves, Hose, Nozzles, Fire Extinguishers, etc., Easily Accessible

COMMENTS/DEFICIENCY DESCRIPTION

Instructions: How to submit this form by email:

1. Download the form to your computer/device and fill in the information.
2. Use the "Email Form" button to submit the completed form by email

For questions or concerns, contact: qap.techservices@delaware.gov

DOC. #75-01-12-09-12