



**DELAWARE STATE FIRE MARSHAL
FIRE ALARM SYSTEM
DEFICIENCY REPAIR FORM**



PROTECTED PROPERTY

Name: _____ Owner/Contact: _____
Address/City: _____ Phone Number: _____

FIRE ALARM SIGNALING SYSTEM COMPANY AND REPAIR DATE

Company Name: _____ FAL #: _____
Technician's Name: _____ Repair Date: _____

SYSTEM INFORMATION

System ID Number: _____ Location: _____
System Type: Central Station Monitored Remote Station Monitored
 Proprietary Local Alarm Only Dialer

PANEL MANUFACTURER: _____ **MODEL NUMBER:** _____

MAJOR DEFICIENCIES CORRECTED

- 7601 – System Out-of-Service / Impaired
- 7602 – Unprotected Residential Corridors
- 7603 – FACP in ALARM / TROUBLE
- 7604 – System Monitoring Out-of-Service

NONE CHECKED BELOW

- 7605 – More than 10% of Initiating Devices Failed
- 7606 – More than 10% of Sounding Devices Failed
- 7607 – Other (Make Comment)

MINOR DEFICIENCIES CORRECTED

- 7620 7626
- 7621 7627
- 7622 7628
- 7623 7629
- 7624 7630
- 7625 7631

NONE CHECKED BELOW

- 7632 7638
- 7633 7639
- 7634
- 7635
- 7636
- 7637

COMMENTS/DEFICIENCY CORRECTION DESCRIPTION

Instructions: How to submit this form by email:

1. Download the form to your computer/device and fill-in the information.
2. Use the "Email Form" button to submit the completed form by email

For questions or concerns, contact: qap.techservices@delaware.gov



DELAWARE STATE FIRE MARSHAL
FIRE ALARM SYSTEM
DEFICIENCY REPAIR FORM



MINOR DEFICIENCIES IDENTIFIED:

- | | | | | | |
|-------------|---|---|-------------|---|---|
| <u>7620</u> | - | Battery / Secondary Power out-of-service | <u>7630</u> | - | Tamper Switch not connected to FASS |
| <u>7621</u> | - | A Battery out-of-date / Corroded | <u>7631</u> | - | Manual Pull Station Obstructed |
| <u>7622</u> | - | Smoke / Heat / Flame Detector Damaged | <u>7632</u> | - | Manual Pull Station Damaged |
| <u>7623</u> | - | Smoke Detector too Close to Diffuser / Vent | <u>7633</u> | - | Bell, Horn / Strobes Damaged |
| <u>7624</u> | - | Smoke Detector / Heat Detector not connected to FAP | <u>7634</u> | - | Bell, Horn / Strobes Lacking Audibility |
| <u>7625</u> | - | Smoke Detector not A/C Powered with Battery Back-Up (Residential) | <u>7635</u> | - | Bell, Horn / Strobes Damaged / Missing |
| <u>7626</u> | - | Inadequate Detector Coverage | <u>7636</u> | - | Device Identification Lacking |
| <u>7627</u> | - | Duct Detector Inoperative | <u>7637</u> | - | Circuit Breaker to FACP no Lockout |
| <u>7628</u> | - | Duct Detector Lacking System Shut-Down | <u>7638</u> | - | Supervisory Function Deficiency |
| <u>7629</u> | - | Flow / Pressure Switch not Connected to FASS | <u>7639</u> | - | Other |