



DELAWARE STATE FIRE MARSHAL RANGE HOOD FIRE SUPPRESSION SYSTEM DEFICIENCY REPAIR FORM



PROTECTED PROPERTY

Name: _____ Owner/Contact: _____
Address/City: _____ Phone Number: _____

SUPPRESSION SYSTEM COMPANY AND REPAIR DATE

Company Name: _____ FSL #: _____
Technician's Name: _____ Repair Date: _____

SYSTEM INFORMATION

System ID Number: _____ Location: _____
System Type: Wet Chemical Dry Chemical Other: _____
Suppression System Mfg. _____ Model Number: _____

MAJOR DEFICIENCIES CORRECTED

NONE CHECKED BELOW

- 7801 – System Out-of-Service / Impaired
- 7802 – Any Unprotected Appliance
- 7803 – Nozzle or Piping Blocked / Obstructed
- 7804 – Lack or Failure of Gas or Electric Shut Off to Appliances

- 7805 – Agent / Expellant Gas Levels Out-of-Range
- 7806 – Exhaust System Out-of-Service
- 7807 – Other (Comments Below)

MINOR DEFICIENCIES CORRECTED

NONE CHECKED BELOW

- 7820- Manual Release Blocked / Obstructed
- 7821- Manual Release Damaged / Missing
- 7822- Grease Laden Filters / Hood / Duct / Area
- 7823- Not Connected to FAS
- 7824- Hydro Test Date Expired
- 7825- Other

COMMENTS/DEFICIENCY CORRECTION DESCRIPTION

Instructions: How to submit this form by email:

1. Download the form to your computer/device and fill-in the information.
2. Use the "Email Form" button to submit the completed form by email

For questions or concerns, contact: qap.techservices@delaware.gov