CODE PURPLE SHELTER (TEMPORARY)

- Requires application, scale plan/drawing, & fee
- Labeled as an Occupancy change (OCC) must have Code Purple in the Project Name
- Temporary permit for shelter
- The shelter shall be considered a Rooming and Lodging Occupancy and shall not have more than 16 patrons not to include the required staff member(s)
- If no FSS, areas designated for sleeping require an exit door directly to the outside. Following the 2012 LSC requirement 26.3.6.2.
- If FSS they can choose to meet the current LSC. Which means patrons can sleep just about anywhere.
- Temporary/battery operated smoke detectors shall be located in sleeping area as well as immediately outside the sleeping area. If there is a FAS smoke detection can be added but is not required.
- The building shall be occupied by another occupancy before a temporary use will be allowed. Vacant buildings wishing to be used shall meet the requirements of the current DSFPRs and NFPA Codes & Standards.